


BACKFLOW CENTRAL

1. Backflow Test Gauge – 3 Valve



Helpful tips to care for your gauge

- Clean line filters regularly
- Disconnect hoses from your gauge and empty water after each test
 - Always store and carry your gauge in its protective carry case
 - Have your gauge tested annually at Backflow Central
- Use in conjunction with the Backflow Central test report book

Specifications

- Differential pressure accuracy +/- 1.33kpa (Descending)
 - Working pressure: 1300kpa
 - Maximum temperature: 65°C

Hoses

Please note that hose colours and lengths may vary according to model supplied and hose availability at the time of purchase.


BACKFLOW CENTRAL

Ph: 1300 734 295

www.backflowcentral.com.au

BACKFLOW CENTRAL


2. Typical RPZ and DCV 1st Check Valve Test: Using BACKFLOW CENTRAL 3 VALVE GAUGE



1. Connect gauge to valve as shown, and as per standard AS2845 test. Use test cock 1 and 2.
2. Open vent and open **High**, close off and open **Low**, close off. Bleed all air from the system.
3. Slowly close , then **Low**. Record all readings.

BACKFLOW CENTRAL

3. Typical RPZ Relief Valve Test: Using BACKFLOW CENTRAL 3 VALVE GAUGE




1. Connect gauge to valve as shown, and as per standard AS2845 test.
2. Test as per 1st check valve test. Test cock 1 and 2 should be open.
High A, **Low B** and bypass should be shut off.
3. Open **High A**.
4. Slowly open **Low B**.
This will allow high pressure water through the gauge into the **blue** middle chamber, equalizing pressure across the 1st check allowing the relief valve to open.
5. Record pressure at which point the relief valve opens.

BACKFLOW CENTRAL

4. Typical Upstream & Downstream

Isolation Valve Test:


Using BACKFLOW CENTRAL 3 VALVE GAUGE



1. Connect gauge to valve as shown, and as per standard AS2845 test. Use test cock 3.
2. Open test tap 3. Vent through **High Side Connection, High A** and Vent C.
3. Close Vent C first, and then Upstream Isolating Valve 4.
4. The gauge will have a high reading.
5. Open **Low B**, and vent pressure through **Low Side Connection** so that gauge drops 20kpa.
6. Close **Low B**.
7. If pressure on gauge rises, either Upstream Isolating Valve 4 or Downstream Isolating Valve 5 is leaking.

BACKFLOW CENTRAL

5. Typical RPZ 2nd Check Valve Test: Using BACKFLOW CENTRAL 3 VALVE GAUGE




1. Connect gauge to valve as shown, and as per standard AS2845 test.
2. Test as per first check valve test, then:-
3. Close Test Tap 2, trapping pressure in the right side of the gauge.
4. Open **High**. Open Test Cock 3. Open Bypass Hose Connection, slowly filling grey downstream side of valve.
5. If relief valve opens, then 2nd check is leaking into the middle chamber. If so, the check valve fails the test.

BACKFLOW CENTRAL

6. Typical DCV and RPZ 2nd Check Valve Test:

(Note: RPZ test is non-standard, but obtains a pressure reading)


Using BACKFLOW CENTRAL 3 VALVE GAUGE



1. Connect gauge to valve as shown, and as per standard AS2845 test. Use test cock 2 and 3.
2. **High A**, **Low B** and Bypass should be shut off. Leave off during this test.
3. Open Vent C. Vent all air from the system.
4. Slowly close **High A** and **Low B**. Record readings.

BACKFLOW CENTRAL

7. Typical Single Check Valve: Using BACKFLOW CENTRAL 3 VALVE GAUGE




1. Connect gauge to valve as shown, and as per standard AS2845 test. Use test cock 1 and 2.
2. Turn off Bypass Ball Valve.
3. Open Test Cock 1, **High A** and Vent C. Open Test Cock 2 and **Low B**.
4. Slowly close **High A** and **Low B**. Record readings.

BACKFLOW CENTRAL

8. Typical Single Check Valve

Metered Bypass Test:

Using BACKFLOW CENTRAL 3 VALVE GAUGE



1. Turn off test cocks 1 and 2.
2. Water meter bypass ball valve should be turned off for the duration of this test.
3. Open Test Cock 3. Initial system pressure in **metering area bypass network** will vent.
4. Once system pressure has vented, there should be no more leakage through Test Cock 3.
5. If there is any further leakage through Test Cock 3, the water is passing in backflow direction through bypass check valve, resulting in a FAIL.